

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20161006- R4339  
**Report Reference** R4339-19910311  
**Issue Date** 2016-October-06

**Issued to:** GCP Applied Technologies Inc  
FIRE OPERATING UNIT  
62 WHITTEMORE AVE  
CAMBRIDGE MA 02140

**This is to certify that  
representative samples of**


SPRAY-APPLIED FIRE-RESISTIVE MATERIALS  
CEMENTITIOUS CEMENT AND PLASTER MIXTURES  
FIRE-RESISTANCE RATINGS - ANSI/UL 263  
SPRAY-APPLIED FIRE RESISTIVE MATERIAL  
CEMENTITIOUS MIXTURES  
FIRE AND SMOKE PROTECTION  
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** SEE ADDENDUM PAGE FOR Standard(s)  
**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20161006- R4339  
**Report Reference** R4339-19910311  
**Issue Date** 2016-October-06


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

A mixture of ingredients which when mixed with water form a cementitious mixture.

Type Designations - Z-146, Z-146 NPP, Z-146PC, Z-146T

## STANDARDS FOR SAFETY:

UL 263, Fire Tests of Building Construction and Materials  
UL 723, Test for Surface Burning Characteristics of Building Materials  
UL 1709, Rapid Rise Fire Tests of Protection Materials for Structural Steel  
ULC-S101, Standard Methods of Fire Endurance Tests of Building Construction and Materials  
ULC-S102M, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

